MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY CCR CERTIFICATION CALENDAR YEAR 2014

2015	JUN	-3		8:	38
------	-----	----	--	----	----

LINE WATER SUPPL

Public Water	r Supply Name
List PWS ID #s for all Community	Water Systems included in this CCR
	h Community public water system to develop and distribute a rear. Depending on the population served by the public water, published in a newspaper of local circulation, or provided to the rocedures when distributing the CCR. You must mail, fax or e check all boxes that apply.
Customers were informed of availability of CCR by	
X Advertisement in local paper (att ☐ On water bills (attach copy of bil ☐ Email message (MUST Email th ☐ Other	e message to the address below)
Date(s) customers were informed: 0/5/	2171 . 210115
CCR was distributed by U.S. Postal Service or omethods used	other direct delivery. Must specify other direct delivery
Date Mailed/Distributed:/_/	
CCR was distributed by Email (MUST Email MSD) \[\Boxed As a URL (Provide URL \\	H a copy) Date Emailed: / /
CCR was published in local newspaper. (Attach copy	y of published CCR or proof of publication)
Name of Newspaper: The News - (Commercial, Collins, MS
Date Published: $5/27/2015$	· ·
CCR was posted in public places. (Attach list of local	tions) Date Posted://
CCR was posted on a publicly accessible internet site	e at the following address (DIRECT URL REQUIRED):
CERTIFICATION I hereby certify that the 2014 Consumer Confidence Republic water system in the form and manner identified the SDWA. I further certify that the information include the water quality monitoring data provided to the public water Supply. Policy Department of Health, Bureau of Public Water Supply. Name/Title (President, Mayor, Owner, etd.)	above and that I used distribution methods allowed by
Deliver or send via U.S. Postal Service: Bureau of Public Water Supply	May be faxed to: (601)576-7800
P.O. Box 1700 Jackson, MS 39215	May be emailed to:

May be emailed to: water.reports@msdh.ms.gov

WATER SUPPL

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources? We sare committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Seminary have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Billy D. Kerolyi, Mayor at 601-722-9428. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 8:00 PM at the Seminary Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January. 1st to December 31st, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up stances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural investock operations, and wildlife; inorganic contaminants, such as satis and metals, which can be naturally occurring or result from urban storm-water runoff, industrial; or domestic wastewater discharges, oil and gas production, mining; or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic centical centical contaminants, including synthetic and votalitie organic centicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided public water systems. Alf drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

	1.5			TEST R	ESUL7	S		
Contaminant	Violatio n Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic (Contai	ninants					into Sa	
10. Barium	Ň	2014	:0055	.00520055	ppm	. 2	1 / 1	Discharge of drilling wastes; discharge from metal refineries; erosion of natur deposits
13. Chromium	N	2014	10.5	9.9 10.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
16. Fluoride	N	2014	415	.389415	ppm	4		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and stuminum factories
17. Lead	N	2012/14	1	0	ppb	0		Corrosion of household plumbing systems, erosion of natural deposits
Volatile Or	ganic	Contan	inants				•	
64. Dichloromethane	N.	2014	1.08	No Range	ppb	0		Discharge from pharmaceutical and chemical factories
76. Xylenes	N	2014	.0007	.00050007	ppm	10		Discharge from petroleum factories; discharge from chemical factories
Disinfection	n Bv-P	roducts	3			1 1 1 1		
81. HAA5	N	2014	11	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total (rihalomethanes]	N	2014	11.5	No Range	ppb	0		By-product of drinking water disinfection.
Chlorine	N	2014	1.9	1.19 - 2.20	ppm	0	MORL = 4	Water additive used to control microbes

Most recent sample. No sample required for 2014.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been slitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-428-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Town of Seminary works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Publish one time: May 27, 2015

Proof of Publication 2015 JUN -3 AN 8: 38

STATE OF MISSISSIPPI COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, **Analyn Arrington Goff**, Publisher of **THE NEWS-COMMERCIAL**, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

Vol113	_ No ⁴⁶	_ DatedMay 27, 2015
Vol	_ No	_ Dated
Vol	_ No	_ Dated
		_ Dated
ana	yn l. I	Publisher
Sworn to and subs	cribed before me,	this the 27th day of
May		, 2015./
	nes Ani	Notery Public
		OF MISS
		ARRING TO THE LEGISLET OF THE PARTY OF THE P
Printer's Fee	\$165.0	10# 72260 NOTARY PUBLIC X
Proof of Publicatio	n \$3.0	00 Dec. 18, 2016
TOTAL	\$168.0	" Granco"